



**BC Transmission**  
CORPORATION

*Building Connections*

Marcel Reghelini  
Director, Regulatory Affairs  
Phone: 604 699-7331  
Fax: 604 699-7537  
E-mail: marcel.reghelini@bctc.com

December 5, 2007

Ms. Erica M. Hamilton  
Commission Secretary  
British Columbia Utilities Commission  
Sixth Floor, 900 Howe Street  
Box 250  
Vancouver, BC V6Z 2N3

**Via e-mail**  
*commission.secretary@bcuc.com*

Dear Ms. Hamilton:

**Re: British Columbia Transmission Corporation (BCTC)  
Project No. 3698486 – Interior to Lower Mainland Transmission Project  
Errata Sheet for Exhibit B-1**

---

BCTC files an Errata Sheet and replacement pages for Exhibit B-1. Replacement pages have a green background and changes are marked by a black line in the right margin.

BCTC also plans to file a set of orthophotos of the Project route with the Commission this week. Initial recipients of the Application may request a CD or printed copy of the orthophotos from BCTC; or download the orthophotos from [www.bctc.com](http://www.bctc.com). BCTC expects to have the orthophotos on [www.bctc.com](http://www.bctc.com) by December 7, 2007.

Sincerely,

*Original signed by:*

Marcel Reghelini  
Director, Regulatory Affairs

Copy: Initial distribution of Application

Suite 1100, Bentall Centre  
1055 Dunsmuir Street  
PO Box 49260  
Vancouver, BC V7X 1V5  
**Telephone:** 604 669 7200  
**Facsimile:** 604 699 7332  
**www.bctc.com**

**Errata Sheet for Exhibit B-1 – ILM Project CPCN Application and Appendices**

**Application**

1. Section 5.1.1 – page 42
  - a. Line 11 – typographical error (Capitalization)
  - b. Line 23 – “ING” is replaced by “Clayburn Substation (CBN)”
  - c. Line 26 to 27 – “Clayburn Substation (CBN)” is replaced with “CBN”
2. Section 8.1.6.2 – page 119
  - a. Table 8-6 – Item 2 – Replace “recommended” with “endorsed” in the sentence, “Magnetic field levels will be below the levels recommended by the World Health Organization.”

**Appendix H – ILM Project Assessment of Need**

3. Section 2.0 – page 6
  - a. Line 4 – “5L42” is replaced by “5L41”
4. Section 2.0 – page 7
  - a. Line 5 – “therefore tend to require an earlier reinforcement of the when” is replaced by “therefore tends to require an earlier reinforcement of the ILM grid when”
5. Section 4.1 – page 10
  - a. Replace Figure 4-1 to add letters “A” and “B” to the “Req Transfer @ Kelly/Nicola” line
6. Section 5.1 – page 12
  - a. Line 5 to 6 – Delete “from incremental load growth minus the net increase in Coastal Generation of about 200 MW for a total 20-year incremental CU of 1400 MW”
  - b. Line 6 – Replace “1600 MW and 2000 MW” with “1800 MW and 2200 MW”
7. Section 5.1 – page 13
  - a. Replace Figures 5-2 and 5-3 to show additional detail
8. Section 5.1 – page 14
  - a. Line 2 – Replace “demand by 2800 MW” with “demand by 2860 MW”
  - b. Line 5 – Replace “demand by 3170 MW” with “demand by 3180 MW”
  - c. Line 6 – Replace “demand by 6460 MW” with “demand by 6100 MW”
  - d. Line 8 – Replace “demand by 3680 MW” with “demand by 3240 MW”
  - e. Line 9 – Replace “demand by 8000 MW” with “demand by 7534 MW”
9. Section 5.1 – page 15
  - a. Replace Figure 5-6 to add missing detail
10. Section 5.2.2.1 – page 20
  - a. Line 6 – Replace “(line C)” with “(line E)”

11. Section 5.2.2.2 – page 22
  - a. Line 6 – Replace “(line C)” with “(line E)”
12. Appendix A – page 29
  - a. Line 5 – Replace “nomogram with one hour continuous thermal rating” with “nomogram with one hour thermal overload rating”

**Appendix I – Reinforcement Alternatives for the ILM Transmission Grid**

13. Section 2.2 – page 19
  - a. Line 17 – Replace “5L46 would likely require new ROW for some of its 203 km.” with “5L46 would likely require new ROW for most of its 203 km.”
14. Section 4.0 – page 38
  - a. Line 24 – Replace with “669 MW” with “450 MW”
  - b. Line 25 – Replace with “517 MW” with “325 MW”

**Appendix K – ILM Horizon Year Total Transfer Capability Study**

15. Section 1 – page 6
  - a. Line 2 – Replace “5800 MW” with “6272 MW to 6355 MW”

1 **5.0 PROJECT DESCRIPTION**

2 **5.1 Project Components and Infrastructure**

3 **PRE-FILED EVIDENCE OF MELISSA HOLLAND, PROJECT MANAGER, ILM**  
4 **PROJECT**

5 The purpose of this section is to describe the ILM Project as proposed by BCTC. The  
6 proposed alternative is a new transmission line (5L83) from NIC to MDN, which will  
7 increase transmission capability for serving customers in the Lower Mainland and on  
8 Vancouver Island.

9 **5.1.1 Existing NIC to MDN Transmission Line Corridor**

10 The first 500 kV AC transmission line constructed between NIC and MDN was circuit  
11 5L82. Circuit 5L82 was completed in 1977 after the completion of the Mica  
12 Generating Station on the Columbia River. It is comprised primarily of guyed and rigid  
13 flat Single Circuit Steel Towers (SCST). Please see Figure 5-1 Interior to Lower  
14 Mainland Transmission Grid.

15 The NIC to MDN corridor also contains portions of circuits 5L81 and 5L41. Circuit  
16 5L81, a 500 kV AC flat SCST circuit between NIC and Ingledow Substation (ING) in  
17 Surrey, was completed in 1976 to also transfer power from the Mica Generating  
18 Station to the Lower Mainland. Circuit 5L81 parallels 5L82 between NIC and Agassiz  
19 and both circuits tie into American Creek Capacitor Station (AMC), north of Hope.  
20 Circuit 5L81 leaves the NIC to MDN corridor at Agassiz to follow the Fraser Valley to  
21 ING.

22 Circuit 5L41, a 500 kV AC flat SCST from Kelly Lake Substation (KLY) near Clinton to  
23 Clayburn Substation (CBN), was completed in 1969 to transfer power to the Lower  
24 Mainland from the Gordon M. Shrum Generating Station on the Peace River. Circuit  
25 5L41 parallels 5L81 and 5L82 between the headwaters of American Creek and Ruby  
26 Creek where it leaves the NIC to MDN corridor to follow the Fraser Valley to CBN  
27 near Abbotsford.

Other public planning activities include public forums and workshops. In 2004 and 2005, the need for additional transmission capacity between the Interior and Lower Mainland was a topic of discussion at BCTC’s annual Provincial Public Forum and Technical Workshop and regional meetings/workshops. The process involved discussions with First Nations and the public.

**8.1.6 Input Received and BCTC Responses**

**8.1.6.1 Consultation Logs**

The consultation logs in Appendix S-8 provide detail on input received and BCTC’s follow-up actions.

The Input Summary Table in Appendix S-9 provides additional information indicating whether comments noted and issues raised were by property owners, municipal and regional government representatives, the general public and interested parties, or all three. It also lists the number of times each topic was raised.

**8.1.6.2 Summary of Issues Raised Through Public Consultation**

Table 8-6 summarizes issues raised during the ILM consultation process and BCTC’s responses to those issues.

**Table 8-6. Issues Raised Through Public Consultation**

<b>Upgrade to Existing Circuits Alternative</b>		
	<b>Issue</b>	<b>Management Of Issue</b>
1	Potential visual impacts	Part of the upgrades to existing circuits includes selectively raising some existing towers 3 to 8 metres or the addition of a tower within an existing transmission line. Visual impacts will be assessed as part of the project if this alternative is selected.
2	Interest and/or concern about electric and magnetic fields (EMF)	Magnetic field levels will be below the levels endorsed by the World Health Organization. Details on sources for information on EMF, including the BC Centre for Disease Control, the World Health Organization and Health Canada, were provided to the public.
3	Concern about nuisance shocks and induction	BCTC explained what nuisance shocks are, how they happen and that there are no safety concerns.

- 1           ▪ 5L81 and 5L82 connect Nicola (NIC) Substation in the South Interior to Ingledow  
2           (ING) and Meridian (MDN) substations in the LM; and
- 3           ▪ 5L42 connects Kelly Lake (KLY) Substation in the Interior to Cheekye (CKY)  
4           Substation and 5L41 connects KLY to Clayburn (CBN) Substation in the LM.

5           Four additional lines allow for power sharing between the substations:

- 6           ▪ 5L45 connects CKY and MDN substations in the LM;
- 7           ▪ 5L44 connects MDN and ING substations in the LM;
- 8           ▪ 5L40 connects CBN an ING substations in the LM; and
- 9           ▪ 5L87 connects NIC and KLY substations in the Interior.

10          Five of the ILM lines (5L41, 5L42, 5L87, 5L81, and 5L82) are series compensated to  
11          increase transfer capability.

12          Usage of the ILM grid is a function of:

- 13               (a) LM and VI load (net of DSM),
- 14               (b) Firm exports/imports, and
- 15               (c) Generation resources in the coastal and interior regions.

16          Flexibility and economics dictate generation dispatch patterns. The transmission  
17          system should be able to accommodate the forecast generation output of the coastal  
18          and interior regions. Additional Independent Power Producers (IPPs) in the coastal  
19          region may partially compensate for the increase in load in the region and slow the  
20          growth in ILM usage. DSM options that provide capacity reductions when the demand  
21          is high will also reduce load growth and slow growth in ILM usage.

22          Dispatch of interior generation to either dependable or maximum levels also affects  
23          the usage of the ILM grid. For transmission planning studies that usually consider the  
24          heaviest coastal loads during the winter, the dependable generation capacities are  
25          usually modeled. These reflect the historical available generation capacities under  
26          winter peak conditions. Sensitivity studies are often performed using maximum

1 generating capacities to stress the transmission system even further. These reflect  
2 how the system may be operated under emergencies or freshet conditions where the  
3 spring runoff is high at all the interior plants and power must be generated or water is  
4 spilled. A maximum dispatch pattern leads to a higher committed use (CU) on the ILM  
5 grid and therefore tends to require an earlier reinforcement of the ILM grid when its  
6 transfer capability is exhausted.

7 When there is available capacity on the ILM grid it can play a role in enabling trade.  
8 When it is economic to do so, power can be exported from the Interior to the US and,  
9 conversely, power from the US and Alberta can be imported and delivered to loads  
10 via the ILM grid.

### 11 **3.0 OBJECTIVES AND PLANNING STANDARDS**

12 BCTC's planning objectives and standards are described in Sections 4.6.1 and 4.6.2  
13 of Exhibit B-1 of BCTC's F2008-2017 Transmission System Capital Plan proceeding  
14 (F2008 TSCP), pages 50 to 59. The objectives are:


- 15 (a) Serving firm load,
- 16 (b) Enabling economic generation dispatch,
- 17 (c) Enabling point-to-point power transfers,
- 18 (d) Affordability,
- 19 (e) System performance,
- 20 (f) Community Impact, and
- 21 (g) Environmental compliance.

#### 22 **3.1 Application of Planning Standards and Objectives**

23 Because of the complexity of the electric system, it is impossible to study all system  
24 operating conditions and permutations of equipment availability. For example, the  
25 load varies from 40 to 100% of peak. The generators are dispatched not only to serve  
26 the load but also to economically extract energy from the reservoirs. The transmission

1 graphical plot known as a nomogram. The nomograms for continuous thermal limits,  
 2 one-hour thermal overload limits, and voltage stability limits for the ILM grid are  
 3 shown in Figure 4-1 and discussed below.

4 **Figure 4-1. ILM Nomograms**




5  
 6 The ILM nomograms help explain the relationship between the sources of generation  
 7 and the TTC, CU and Available Transfer Capability (ATC) of the ILM grid. Figure 4-1  
 8 also displays the following:

- 9 (a) "LM & VI Load and Losses line" is a 45-degree locus of the winter peak load  
 10 and losses to be served in the coastal region. This line moves upward and to  
 11 the right if the load increases, and moves downward and to the left if the load  
 12 decreases.
- 13 (b) "Required transfer at Kelly and Nicola line" is also a 45-degree locus of all the  
 14 combinations of transfer from the NI and SI that meet the LM & VI Load and  
 15 Losses requirement after the dispatch of Coastal Generation. As more Coastal



1 and VI peak load forecasts and generation for the next 20 years are shown in Figures  
 2 5-1, 5-2, and 5-3 for the amended LTAP and Contingency Resource Portfolios. There  
 3 is a growing imbalance between load and supply in the LM and VI regions. The  
 4 20-year incremental CU from Figure 5-1 (amended LTAP portfolio) is approximately  
 5 1600 MW. Similarly, the 20-year incremental CU for Contingency Resource Plans  
 6 (CRP) 1 and 2 in Figures 5-2 and 5-3 is approximately 1800 MW and 2200 MW,  
 7 respectively.


8 **Figure 5-1. Total Generation and Load in LM and VI – 2006 Amended LTAP**



9

1  
2


**Figure 5-2. Total Generation and Load in LM and VI – 2006 Contingency Resource Plan 1**



3

4  
5

**Figure 5-3. Total Generation and Load in LM and VI – 2006 Contingency Resource Plan 2**




6

7  
8  
9  
10

While demand is forecast to exceed supply in the coastal region, the opposite is true for the Interior. Figures 5-4, 5-5 and 5-6 show the forecast load and resources for each of the amended LTAP portfolio and CRPs. These figures show the Interior resource additions both in terms of their dependable and maximum capacities.

1 The Interior incremental dependable generation capacity exceeds the incremental  
 2 demand by 2860 MW by F2027, while the incremental Interior maximum generation  
 3 capacity exceeds the incremental demand by 4780 MW for the amended LTAP  
 4 portfolio by F2027. For CRP1, the Interior region incremental dependable generation  
 5 capacity exceeds the incremental demand by 3180 MW (F2027), while the  
 6 incremental maximum generation capacity exceeds the incremental demand by 6100  
 7 MW (F2027). For CRP2, the Interior incremental dependable generation capacity  
 8 exceeds the incremental demand by 3240 MW (F2027), while the incremental  
 9 maximum generation capacity exceeds the incremental demand by 7534 MW  
 10 (F2027).


11 **Figure 5-4. Total Generation and Load in Interior Regions – 2006 Amended**  
 12 **LTAP**



13


1  
2

**Figure 5-5. Total Generation Additions and Load Growth in Interior Regions – 2006 Contingency Resource Plan 1**




3  
4  
5  
6

**Figure 5-6. Total Generation Additions and Load Growth in Interior Regions – 2006 Contingency Resource Plan 2**



7

1

**Figure 5-10. ILM Nomogram for CRP1 F2015**


2

3 In 2014\15, Burrard Generating Station and the CE are no longer forecast to be  
 4 available to be dispatched as Coastal Generation. The dispatch of the remaining  
 5 dependable Coastal Generation results in the KLY and NIC transfer line (line B) being  
 6 above the continuous rating of the system (line E) and the voltage stability limit  
 7 (line D). Under this scenario, the ATC is negative by about 1250 MW and illustrates  
 8 the need for increased transfer capability on the ILM grid in 2014.

### 9 5.2.2.2 ILM Nomogram for CRP 2

10 ILM transfers for CRP 2 for the years 2013 and 2014 are shown in Figures 5-11 and  
 11 5-12, respectively.

1

**Figure 5-12. ILM Nomogram CRP2 F2015**

2

3 In 2014\15, Burrard Generating Station and the CE are no longer forecast to be  
 4 available to be dispatched as coastal resources under CRP 2. The dispatch of the  
 5 remaining Coastal Generation results in the KLY and NIC transfer line (line B) being  
 6 above the continuous rating of the system (line E) and above the voltage stability limit  
 7 (line D). The ATC of the ILM grid is negative by about 1500 MW and this illustrates  
 8 the need for the ILM reinforcement in 2014.

### 9 5.2.2.3 ILM Cut-Plane Observations for LTAP and Contingency Portfolios

- 10 (a) An increase in ILM transfer capability is needed at its earliest in-service date  
 11 of 2014 for the Amended LTAP portfolio as well as for the Commission  
 12 approved CRPs 1 and 2.
- 13 (b) In the absence of Burrard Generating station and the CE by 2014, all three  
 14 portfolios exceed the existing continuous thermal limits of the existing ILM  
 15 grid.
- 16 (c) All three portfolios exceed the existing voltage stability limits without Burrard  
 17 Generating Station.

The need for increased transfer capacity on the ILM grid was also analyzed in the 2004 NITS studies, in studies prior to the submission of the BC Hydro's 2006 IEP application, and in studies during BC Hydro's 2006 IEP/LTAP proceeding. All of these studies used the N-1 thermal nomogram with one hour thermal overload rating of the existing ILM grid to determine timing of the peak hour negative ATC of the grid. Each study was conducted based on the latest set of available load forecasts, the most likely resource scenarios, and the firm export possibilities at the time of study. The analysis data and assumptions are listed in Table A-3.

**Table A-3. Analysis Data and Assumptions**

	<b>Studies</b>	<b>Load Forecast</b>	<b>Resource Portfolios</b>	<b>Export Western Inter-tie</b>
1	NITS2004 (8 scenarios)	October 2004 coincidental normal and high	Base resource plan, Alternative 1, Alternative 2, Alternative 3	230 MW and 730 MW
2	Before 2006 IEP Submission (17 scenarios)	December 2005 coincidental normal and high	Coal, Low air impacts, Low land impacts, Diverse technology, 100% Green, Low cost (mid GHG), Low cost (GHG@ \$10/tonne), Maintain Burrard, Low cost (3000 GWh import), Maintain Burrard for capacity, Low cost without Site C, Burrard re-powering, Low cost (up to 6000 GWh imports), Security of supply with insurance, Low air impact w/o EE3 or 4 or 5, Security of Supply, Low cost impact w/o EE3 or 4 or 5	230 MW
3	During 2006 IEP Submission (18 scenarios)	December 2006 coincidental normal and high	LTAP+Max Interior Dispatch, CRP1+Max Interior Dispatch, CRP2+Max Interior Dispatch, LTAP+Max Interior Dispatch+BGS repowering, CRP1+Max Interior Dispatch+BGS repowering, CRP2+Max Interior Dispatch+BGS repowering, LTAP+Max Interior Dispatch+BGS repowering+CE, CRP1+Max Interior Dispatch+BGS repowering+CE, CRP2+Max Interior Dispatch+BGS repowering+CE, LTAP+Dep Interior Dispatch, CRP1+Dep Interior Dispatch, CRP2+Dep Interior Dispatch, LTAP+Dep Interior Dispatch+BGS repowering, CRP1+Dep Interior Dispatch+BGS repowering, CRP2+Dep Interior Dispatch+BGS repowering, LTAP+Dep Interior Dispatch+BGS repowering+CE, CRP1+Dep Interior Dispatch+BGS repowering+CE, CRP2+Dep Interior Dispatch+BGS repowering+CE	230 MW

1           These nomograms illustrate that 5L83 and UEC alternatives provide higher  
2           incremental ILM thermal transfer capabilities from the NIC side. The 5L46 circuit  
3           enhances thermal transfer capabilities from the KLY side but has limited impact on  
4           the NIC side.

5           In BC Hydro's Amended LTAP, CRP1, and CRP2, most of the future resources would  
6           be in the South Interior region. Transferring dependable capacity of these resources  
7           to the LM and VI would require improvements in the transfer capability of the ILM grid  
8           from the NIC side. Consequently, 5L83, and UEC would better match the LTAP,  
9           CRP1, and CRP2 requirements from a thermal perspective and 5L83 would be a  
10          better voltage stability match. In a longer planning horizon, it is likely that 5L46 will  
11          still be needed to address requirements for increased transfer capability from the NI,  
12          but that is not the present need.

13          5L46 would also not reduce system losses to the same extent as 5L83. Estimated  
14          annual losses, at 6750 MW ILM flow and 2000 MW flow from KLY, are forecast to be  
15          1009 GWh for a 5L46-reinforced ILM grid as compared with 882 GWh with a 5L83-  
16          reinforced grid.

17          5L46 would likely require new ROW for most of its 203 km. 5L46 was also found to  
18          require more double outage generation shedding and load shedding than 5L83 or  
19          alternatives addressing ILM transfer capability from the NIC side.

### 20    **2.3    New Line NIC to ING**

21          NIC to ING is expected to have similar performance to 5L83 from a one-hour thermal,  
22          continuous thermal, and voltage stability perspective. Therefore, it would address the  
23          need for incremental TTC of the ILM grid. NIC to ING would also be expected to have  
24          similar loss performance to 5L83 and, as discussed below, would be superior to UEC  
25          in this respect.

26          Terminating the new line at ING would increase the firm transfer capability to ING  
27          relative to 5L83 (terminating at MDN). This could facilitate additional electricity trade  
28          opportunities on the western inter-tie. However, the domestic load requirements and  
29          firm export commitments would be met by the increased transfer capability provided  
30          by 5L83.



- 1 Comparison of these two alternatives indicated that:
- 2 (a) For peak hour operating points when KLY transfers are between 1000 MW and  
3 2000 MW, the continuous thermal capabilities of the UEC and 5L83 alternatives  
4 vary between 6000 MW and 6570 MW for UEC and between 6220 MW and  
5 6750 MW for 5L83.
- 6 (b) For most peak hour operating points, the thermal overload capacities of the  
7 5L83 and UEC alternatives are similar.
- 8 (c) With the addition of 470 MVar reactive power support, the 5L83 and the UEC  
9 alternatives would increase the voltage stability of the ILM grid to 7120 MW and  
10 6355MW respectively. Higher voltage stability levels for both alternatives would  
11 require excessive reactive power reinforcements and are not considered  
12 efficient.
- 13 (d) Compared to the UEC alternative, 5L83 would save approximately 307 GWh/yr  
14 in the ILM transmission losses.
- 15 (e) For energy valued at \$74.0/MWh, the PV of costs for 5L83 would be \$373.4 M  
16 less than the PV of costs for UEC alternative. The difference in the PV of costs  
17 is mainly attributed to lower transmission energy losses associated with 5L83.
- 18 (f) Building 5L83 in 2014 and following it by a limited number of UEC upgrades in  
19 2020 would be less expensive than implementing the UEC in 2014 and delaying  
20 5L83 to 2019. The difference in the PV of costs between the two long-term  
21 planning sequences would be approximately \$150 M and would be mainly  
22 attributed to the 5L83 transmission loss savings between 2014 and 2019.
- 23 (g) Double outage generation shedding requirements for 5L83 would be between  
24 450 MW and 1255 MW less than similar requirements for the UEC alternative.
- 25 (h) Double outage load shedding requirements for 5L83 would be between 325 MW  
26 and 1060 MW less than similar requirements for the UEC alternative.
- 27 (i) Both 5L83 and UEC reinforcement alternatives would make similar  
28 improvements in the EENS performance of the bulk transmission grid.

1 not be able to increase the voltage stability limits of the system beyond  
2 approximately 6272 MW to 6355 MW and a new transmission line would eventually  
3 be required in combination with new reactive reinforcements to maximize the  
4 capability of the ILM grid.

5 In the second part of the study, the ILM voltage stability limits are determined if  
6 5L83 were added. Voltage stability and thermal reinforcements are then  
7 determined to maximize the capability of the five line system.

8 Finally, voltage stability and thermal limits are determined should 5L46, a sixth line,  
9 be added to the ILM grid and further reactive and thermal enhancements are  
10 determined to maximize the voltage stability and thermal limits of the six line  
11 system.

12 The 500 kV transmission system configurations in 2016, 2026 and 2036 are  
13 provided in Appendix A.

14 Horizon year studies by their very nature are forward-looking and uncertain. The  
15 selection of future options is determined by using BCTC's knowledge of the  
16 transmission system and by examining the most likely and practical reinforcement  
17 options with existing information. In the absence of full information, horizon year  
18 studies provide important information to demonstrate that mid-term reinforcements  
19 are compatible with a long term vision of the transmission system.

## 20 **2 STUDY ASSUMPTIONS**

### 21 **2.1 The Study Year of Interest**

22 To assess the voltage stability limit of the existing ILM grid and compare the  
23 voltage stability limits among several possible transmission system upgrade  
24 options in near-term, all of the near-term study cases were developed from the  
25 original F2009 PSS/E heavy winter base case. 2016 is selected as the mid-term  
26 case and 2026 and 2036 are the horizon year study periods.