



# **Interior to Lower Mainland Transmission Project Assessment of Need**

**Report No: SPA2007- 25  
Final Version  
October 2007**

**Transmission System Planning  
British Columbia Transmission Corporation**

© British Columbia Transmission Corporation, 2007. All rights reserved.

1

## TABLE OF CONTENTS

2	<b>Executive Summary</b>		<b>3</b>
3	<b>1.0</b>	<b>Introduction and Purpose</b>	<b>4</b>
4	<b>2.0</b>	<b>Description of Existing ILM Grid</b>	<b>5</b>
5	<b>3.0</b>	<b>Objectives and Planning Standards</b>	<b>7</b>
6		3.1 Application of Planning Standards and Objectives	7
7	<b>4.0</b>	<b>Limits of THE Existing ILM Grid</b>	<b>8</b>
8		4.1 Nomograms	9
9	<b>5.0</b>	<b>Drivers</b>	<b>11</b>
10		5.1 Demand and Supply Analysis	11
11		5.2 Gap Analysis	16
12		5.2.1 Earlier Studies	16
13		5.2.2 ILM Cut-plane Single Contingency Nomogram Analysis	17
14	<b>6.0</b>	<b>Probabilistic Reliability Analysis</b>	<b>23</b>
15	<b>7.0</b>	<b>Conclusion</b>	<b>24</b>

16

17

## LIST OF FIGURES

18	Figure 2-1. Interior to Lower Mainland Grid Map		5
19	Figure 4-1. ILM Nomograms		10
20	Figure 5-1. Total Generation and Load in LM and VI – 2006 Amended LTAP		12
21	Figure 5-2. Total Generation and Load in LM and VI – 2006 Contingency		
22	Resource Plan 1		13
23	Figure 5-3. Total Generation and Load in LM and VI – 2006 Contingency		
24	Resource Plan 2		13
25	Figure 5-4. Incremental Total Generation Additions and Load Growth in		
26	Interior Regions – 2006 Amended LTAP		14
27	Figure 5-5. Incremental Total Generation Additions and Load Growth in		
28	Interior Regions – 2006 Contingency Resource Plan 1		15
29	Figure 5-6. Incremental Total Generation Additions and Load Growth in		
30	Interior Regions – 2006 Contingency Resource Plan 2		15
31	Figure 5-7. ILM Nomogram for Amended LTAP Portfolio 2013\14		17
32	Figure 5-8. ILM Nomogram for Amended LTAP Portfolio 2014\15		18
33	Figure 5-9. ILM Nomogram for CRP 1 2013\14		19
34	Figure 5-10. ILM Nomogram for CRP 1 2014\15		20
35	Figure 5-11. ILM Nomogram CRP 2 2013\14		21
36	Figure 5-12. ILM Nomogram CRP 2 2014\15		22
37	Figure 6-1. Saving on Risk Cost – ILM vs. Do-nothing		23

1

2

3

**LIST OF TABLES**

4 Table A-1. 2006 IEP Incremental Transmission Facilities.....27

5 Table A-2. Resource Portfolios Reviewed During 2006 IEP Hearings.....28

6 Table A-3. Analysis Data and Assumptions .....29

7

8

1

**LIST OF ABBREVIATIONS**

<b>Abbreviation</b>	<b>Definition</b>
ATC	Available Transfer Capability
BCTC	British Columbia Transmission Corporation
CBN	Clayburn Substation
CE	Canadian Entitlement
CKY	Cheekye Substation
CRP	Contingency Resource Plan
CU	Committed Use
DSM	Demand Side Management
EENS	Expected Energy Not Served
IEP	Integrated Electricity Plan
ILM	Interior to Lower Mainland
ISD	In-Service Date
KLY	Kelly Lake Substation
LM	Lower Mainland
LTAP	Long Term Acquisition Plan
MDN	Meridian Substation
NERC	North American Electric Reliability Council
NIC	Nicola Substation
NITS	Network Integration Transmission Service
TSCP	Transmission System Capital Plan
TTC	Total Transfer Capability
VI	Vancouver Island
WECC	Western Electricity Coordinating Council

2

1

**DISCLAIMER OF WARRANTY, LIMITATION OF LIABILITY**

2

This report is prepared by BCTC solely for the purposes described in this report, and is based on information available to BCTC as of the date of this report. Accordingly, this report is suitable only for such purposes, and is subject to any changes arising after the date of this report.

3

4

5

6

Unless otherwise expressly agreed by BCTC, BCTC does not, except for the purposes for which BCTC prepared the report, represent or warrant the accuracy, completeness or usefulness of this report, or any information contained in this report, for use or consideration by any third party, nor does BCTC accept any liability out of reliance by a third party on this report, or any information contained in this report, or for any errors or omissions in this report. Any use or reliance by third parties is at their own risk.

7

8

9

10

11

12

## 1 EXECUTIVE SUMMARY

2 The purpose of this report is to examine the need for the Interior to Lower Mainland  
3 (ILM) Transmission Project.

4 The ILM transmission grid (defined below) is the most critical transmission path in BC.  
5 In addition to transmitting electricity from the Interior to the Lower Mainland (LM) and  
6 Vancouver Island (VI), where almost 70% of provincial demand is located, the ILM  
7 grid is also a key transmission path for both firm and non-firm electricity trading  
8 activity.

9 A review of the results presented in this study leads to the following conclusions:

- 10 1. The majority of resource portfolios analyzed to date require an increase in the  
11 transfer capability of the ILM grid as early as 2014; and
- 12 2. Some portfolios indicate a deferral of the required increase by one to 9 years.

13 Without an increase in transfer capability, the existing ILM grid will not be adequate  
14 for the reliable transfer of future Interior generation resources to serve load in the LM  
15 and VI. By 2014, The system will not meet the NERC/WECC Planning Standards for  
16 most of the portfolios considered.

17 BCTC needs to plan the transmission system to meet those scenarios that require  
18 additional ILM transfer capability as early as 2014 as well as dealing with scenarios  
19 where the need for incremental capacity might arise later. Should greater Coastal  
20 Generation and/or Demand Side Management (DSM) materialize than the amounts  
21 forecast in those scenarios that require earlier ILM transfer capability additions, it  
22 would tend to defer the need for incremental ILM transfer capability. In that event,  
23 BCTC would be in a position to consider its impact on the timing of the ILM Project.  
24 However, because BCTC must be able to deal with scenarios that require earlier in  
25 service dates, proceeding with the approvals required to increase the transfer  
26 capability of the ILM grid and preserving an in-service date as early as 2014 is  
27 recommended.

## 1 **1.0 INTRODUCTION AND PURPOSE**

2 The purpose of this report is to examine the need for increasing the capacity of the  
3 ILM grid. The report is structured as follows;


4	Introduction and Purpose	(Section 1.0)
5	Description of the ILM grid	(Section 2.0),
6	Objectives and Planning Standards	(Section 3.0),
7	Limits of the Existing ILM Grid	(Section 4.0),
8	Drivers	(Section 5.0)
9	Probabilistic Reliability Analysis	(Section 6.0), and,
10	Conclusion	(Section 7.0).

11 The study uses the BC Hydro 2006 Amended Long Term Acquisition Plan (LTAP)  
12 Portfolios including the two approved Contingency Resource Plans as described in  
13 Exhibit B-1E and amended by Exhibit B-55 and updated in Exhibit B-146A of BC  
14 Hydro's 2006 Integrated Electricity Plan (IEP)/LTAP proceeding. The study also  
15 documents the extensive portfolio analysis done in previous Network Integration  
16 Transmission Service (NITS) System Impact Studies and for the BC Hydro 2006 IEP  
17 filing in which the transmission implications of seventeen portfolios were analyzed. In  
18 addition, during the IEP proceedings, BCTC analyzed the transmission impact of re-  
19 powering Burrard and the return of the Canadian Entitlement (CE). In total 43  
20 portfolios have been examined. The study results are discussed and evaluated and  
21 the need for the ILM Project is presented in the Conclusions section.

## 2.0 DESCRIPTION OF EXISTING ILM GRID

The ILM grid, shown in Figure 2-1, is the most critical transmission path in BC. The ILM grid transmits electricity from the Interior, where the majority of generation is located, to the LM and VI, which together comprise approximately 70% of provincial demand. The ILM grid is also a key transmission path for both firm and non-firm trading activity.

**Figure 2-1. Interior to Lower Mainland Grid Map**



The ILM grid comprises eight 500 kV transmission lines. The power transfer from the Interior to the LM and VI takes place over four of these lines:



1           ▪ 5L81 and 5L82 connect Nicola (NIC) Substation in the South Interior to Ingledow  
2           (ING) and Meridian (MDN) substations in the LM; and

3           ▪ 5L42 connects Kelly Lake (KLY) Substation in the Interior to Cheekye (CKY)  
4           Substation and 5L42 connects KLY to Clayburn (CBN) Substation in the LM.

5           Four additional lines allow for power sharing between the substations:

6           ▪ 5L45 connects CKY and MDN substations in the LM;

7           ▪ 5L44 connects MDN and ING substations in the LM;

8           ▪ 5L40 connects CBN an ING substations in the LM; and

9           ▪ 5L87 connects NIC and KLY substations in the Interior.

10          Five of the ILM lines (5L41, 5L42, 5L87, 5L81, and 5L82) are series compensated to  
11          increase transfer capability.

12          Usage of the ILM grid is a function of:

13               (a) LM and VI load (net of DSM),

14               (b) Firm exports/imports, and

15               (c) Generation resources in the coastal and interior regions.

16          Flexibility and economics dictate generation dispatch patterns. The transmission  
17          system should be able to accommodate the forecast generation output of the coastal  
18          and interior regions. Additional Independent Power Producers (IPPs) in the coastal  
19          region may partially compensate for the increase in load in the region and slow the  
20          growth in ILM usage. DSM options that provide capacity reductions when the demand  
21          is high will also reduce load growth and slow growth in ILM usage.

22          Dispatch of interior generation to either dependable or maximum levels also affects  
23          the usage of the ILM grid. For transmission planning studies that usually consider the  
24          heaviest coastal loads during the winter, the dependable generation capacities are  
25          usually modeled. These reflect the historical available generation capacities under  
26          winter peak conditions. Sensitivity studies are often performed using maximum

1 generating capacities to stress the transmission system even further. These reflect  
2 how the system may be operated under emergencies or freshet conditions where the  
3 spring runoff is high at all the interior plants and power must be generated or water is  
4 spilled. A maximum dispatch pattern leads to a higher committed use (CU) on the ILM  
5 grid and therefore tend to require an earlier reinforcement of the when its transfer  
6 capability is exhausted.

7 When there is available capacity on the ILM grid it can play a role in enabling trade.  
8 When it is economic to do so, power can be exported from the Interior to the US and,  
9 conversely, power from the US and Alberta can be imported and delivered to loads  
10 via the ILM grid.

### 11 **3.0 OBJECTIVES AND PLANNING STANDARDS**

12 BCTC's planning objectives and standards are described in Sections 4.6.1 and 4.6.2  
13 of Exhibit B-1 of BCTC's F2008-2017 Transmission System Capital Plan proceeding  
14 (F2008 TSCP), pages 50 to 59. The objectives are:

- 15 (a) Serving firm load,
- 16 (b) Enabling economic generation dispatch,
- 17 (c) Enabling point-to-point power transfers,
- 18 (d) Affordability,
- 19 (e) System performance,
- 20 (f) Community Impact, and
- 21 (g) Environmental compliance.

#### 22 **3.1 Application of Planning Standards and Objectives**

23 Because of the complexity of the electric system, it is impossible to study all system  
24 operating conditions and permutations of equipment availability. For example, the  
25 load varies from 40 to 100% of peak. The generators are dispatched not only to serve  
26 the load but also to economically extract energy from the reservoirs. The transmission

1 system requires planned maintenance during the year which requires equipment  
2 outages. The locations and sizes of future loads and resources are uncertain.

3 To manage this complexity and uncertainty, models of the future system are  
4 developed to test the system under maximum stressed conditions with the most  
5 critical element out of service. The results of these tests are compared to the planning  
6 standards. If the system meets the planning standards during reasonable worst-case  
7 scenarios, then it is likely that the CU will not exceed the total transfer capability  
8 (TTC) under less stressed conditions.

9 It is important to appreciate that capacity increases required for the most stressed  
10 cases provide reliability benefits under normal conditions. Increases in transfer  
11 capability that meet the planning standards but are only available for a short period of  
12 time provide little if any real reliability improvement to the system. For example,  
13 providing a load curtailment option or generation redispatch option that only is  
14 available for a few hours during the peak period will not provide the same level of  
15 reliability as a capacity increase that is available all year.

#### 16 **4.0 LIMITS OF THE EXISTING ILM GRID**

17 Transmission systems are constrained by a number of single contingency limits.

18 Each of these limits is described in Section 4.6.2 of Exhibit B-1 of BCTC's F2008  
19 TSCP, pages 55 to 59. Representative N-1 single contingency limits of the ILM grid  
20 are discussed below.

##### 21 (a) Continuous Thermal Limits

22 For the ILM grid the continuous thermal limit is defined by the rating of the  
23 series capacitors banks in the ILM grid. This corresponds to a maximum  
24 continuous transfer of approximately 5000 MW.

##### 25 (b) One-Hour Thermal Overload Limits

26 A one-hour thermal overload rating gives the operator time to redispatch  
27 available Coastal Generation or increase imports to reduce the ILM transfer to  
28 within the continuous thermal limit. The one-hour thermal overload limit for the  
29 existing ILM grid is approximately 6300 MW.

1 (c) Voltage Stability Limits

2 Voltage stability is the ability of a power system to maintain steady acceptable  
3 voltages at all buses in the system under normal operating conditions and  
4 after a contingency. A system enters a state of voltage instability when a  
5 disturbance, increase in load demand, or change in system condition causes a  
6 progressive and uncontrollable drop in voltage. The main factor causing  
7 instability is the inability of the power system to meet the demand for reactive  
8 power. Exceeding this limit could result in cascading system outages. The  
9 voltage stability limit of the existing ILM grid is approximately 5800 MW.

10 (d) Transient Stability Limits

11 Transient stability is a condition in which, following a system disturbance, a  
12 generator or group of generators will return to pre-disturbance rotational  
13 speed and will not lose synchronism with the integrated system.

14 After a disturbance, the generators' output in one area will oscillate against the  
15 generators' output in other parts of a large area interconnected system. An  
16 interconnected system must have sufficient damping so that power oscillations  
17 dissipate quickly.

18 Transient stability simulations have confirmed that the power system remains  
19 transiently stable at transfer limits at or below the voltage stability limits of the ILM  
20 grid. Hence, voltage stability is the dominant constraint on the ILM grid relative to  
21 transient stability.


22 The full one-hour thermal overload rating cannot be used during peak load periods  
23 given the lower voltage stability rating. To the extent that the one-hour thermal  
24 overload rating can be used up to the voltage stability rating, if a single contingency  
25 outage lasts for more than one hour then Coastal Generation or imports would need  
26 to be re-dispatched to reduce the ILM grid loading to its continuous thermal rating.

27 **4.1 Nomograms**

28 The N-1 thermal and voltage stability limits described above are represented by  
29 single numbers for simplicity. Each limit is actually a range of values illustrated by a

graphical plot known as a nomogram. The nomograms for continuous thermal limits, one-hour thermal overload limits, and voltage stability limits for the ILM grid are shown in Figure 4-1 and discussed below.

**Figure 4-1. ILM Nomograms**



The ILM nomograms help explain the relationship between the sources of generation and the TTC, CU and Available Transfer Capability (ATC) of the ILM grid. Figure 4-1 also displays the following:

- (a) "LM & VI Load and Losses line" is a 45-degree locus of the winter peak load and losses to be served in the coastal region. This line moves upward and to the right if the load increases, and moves downward and to the left if the load decreases.
- (b) "Required transfer at Kelly and Nicola line" is also a 45-degree locus of all the combinations of transfer from the NI and SI that meet the LM & VI Load and Losses requirement after the dispatch of Coastal Generation. As more Coastal

- 1            Generation is added, the line moves down to the left and, as more load is  
2            added, the line moves up to the right.
- 3            (c) The “Maximum KLY Transfer line” line defines the maximum amount of surplus  
4            NI generation flowing through KLY to the ILM grid. This dashed line is parallel to  
5            the horizontal axis.
- 6            (d) The “Maximum NIC Transfer line” defines the maximum amount of surplus SI  
7            generation flowing through NIC to the ILM grid. This dashed line is parallel to  
8            the vertical axis.
- 9            (e) “Points A and B are the intersection of the Required Transfer at KLY and NIC  
10           line with the Maximum KLY Transfer line and the Maximum NIC Transfer line,  
11           respectively. Both these points must be below and to the left of the voltage and  
12           thermal ratings of the ILM grid for the system to be operated in an acceptable  
13           region of the nomogram while providing dispatch flexibility. For example, for the  
14           first hour after an outage, these points must be below and to the left of the  
15           voltage stability ratings and the one-hour thermal ratings. After the first hour,  
16           these points must be further moved below and to the left of the continuous  
17           thermal limit by re-dispatching additional Coastal Generation or imports if  
18           available. As the load grows and the Coastal Generation is fully utilized, these  
19           points will move beyond the limits of the ILM grid and transmission capacity  
20           increases must be added or additional imports scheduled to allow these points  
21           to continue to be below and to the left of the limits. From the example indicated  
22           in Figure 4-1, sufficient NI or SI coincident generation dispatch flexibility is not  
23           available in relation to the continuous rating of the ILM grid as the locus points  
24           are on the right side of the continuous rating nomogram. Whereas sufficient NI  
25           or SI coincident generation dispatch flexibility is available with the one hour  
26           rating as the locus points are on left side of the one hour rating nomogram.


## 27    **5.0    DRIVERS**

### 28    **5.1    Demand and Supply Analysis**

29            The ILM grid supplies the load in the coastal region from surplus power generated in  
30            the Interior. If resource additions to meet forecast load growth come from the Interior  
31            instead of from the coastal region, the usage of the ILM grid will increase. The LM

1 and VI peak load forecasts and generation for the next 20 years are shown in Figures  
 2 5-1, 5-2, and 5-3 for the amended LTAP and Contingency Resource Portfolios. There  
 3 is a growing imbalance between load and supply in the LM and VI regions. The 20-  
 4 year incremental CU from Figure 5-1 (amended LTAP portfolio) is approximately 1600  
 5 MW from incremental load growth minus the net increase in Coastal Generation of  
 6 about 200 MW for a total 20-year incremental CU of 1400 MW. Similarly, the 20-year  
 7 incremental CU for Contingency Resource Plans (CRP) 1 and 2 in Figures 5-2 and 5-  
 8 3 is approximately 1600 MW and 2000 MW, respectively.


9 **Figure 5-1. Total Generation and Load in LM and VI – 2006 Amended LTAP**



10

1  
2


**Figure 5-2. Total Generation and Load in LM and VI – 2006 Contingency Resource Plan 1**



3

4  
5

**Figure 5-3. Total Generation and Load in LM and VI – 2006 Contingency Resource Plan 2**



6

7

While demand is forecast to exceed supply in the coastal region, the opposite is true for the Interior. Figures 5-4, 5-5 and 5-6 show the forecast load and resources for each of the amended LTAP portfolio and CRPs. These figures show the Interior resource additions both in terms of their dependable and maximum capacities.

8


9

10



1 The Interior incremental dependable generation capacity exceeds the incremental  
 2 demand by 2800 MW by F2027, while the incremental Interior maximum generation  
 3 capacity exceeds the incremental demand by 4780 MW for the amended LTAP  
 4 portfolio by F2027. For CRP1, the Interior region incremental dependable generation  
 5 capacity exceeds the incremental demand by 3170 MW (F2027), while the  
 6 incremental maximum generation capacity exceeds the incremental demand by 6460  
 7 MW (F2027). For CRP2, the Interior incremental dependable generation capacity  
 8 exceeds the incremental demand by 3680 MW (F2027), while the incremental  
 9 maximum generation capacity exceeds the incremental demand by 8000 MW  
 10 (F2027).


11 **Figure 5-4. Total Generation and Load in Interior Regions – 2006 Amended**  
 12 **LTAP**



13


1  
2

**Figure 5-5. Total Generation Additions and Load Growth in Interior Regions – 2006 Contingency Resource Plan 1**



3  
4  
5  
6

**Figure 5-6. Total Generation Additions and Load Growth in Interior Regions – 2006 Contingency Resource Plan 2**



7

## 5.2 Gap Analysis

### 5.2.1 Earlier Studies

Since 2004, BCTC has performed numerous studies to examine the need and timing of increased transfer capability on the ILM grid. These studies include:

(a) The NITS 2004 series of studies which examined eight alternative resource portfolios, and combinations of exports, each of which required increased transfer capability of the ILM grid at its earliest in-service date. These studies formed the basis of the Network Integrated Transmission Service contract which BCTC currently has with BC Hydro.

(b) The portfolio analysis conducted for BC Hydro's 2006 IEP Application in which seventeen portfolios were studied to determine their transmission implications. Thirteen of the portfolios showed a requirement to increase the transfer capability of the ILM grid as soon as possible, three portfolios showed a delay from 1 to 7 years, and one portfolio was constructed so as not to require any increased transfer capability on the ILM grid. This analysis can be found in Exhibit B-1C, Appendix H of the BC Hydro IEP/LTAP proceeding and is summarized in Appendix A of this report.


(c) 18 portfolios analyzed at the request of the Commission during the BC Hydro IEP/LTAP proceeding constituting variations on the capacity available from Burrard and the CE and combinations of maximum vs. dependable dispatch patterns. These portfolios showed that increased transfer capability on the ILM grid was required at its earliest date in 10 of the 18 portfolios, and that the increase could be delayed by 3 to 9 years with high dispatch levels of Burrard and the CE and by using Dependable Generation Capacities. This analysis was filed as Exhibit B-146A in the BC Hydro IEP/LTAP proceeding and is summarized in Appendix A of this report.

(d) Most recently, BCTC has studied the transmission implications of the Amended LTAP and Commission-approved CRPs to assess the need for and timing of increased transfer capability on the ILM grid. An explanation of methodology that went into this analysis is in the following sections.

## 5.2.2 ILM Cut-plane Single Contingency Nomogram Analysis


The single contingency analysis of thermal and voltage stability limit violations for the ILM grid during the peak load are analyzed using nomograms. These nomograms illustrate if sufficient ATC is available to meet the LM and VI load and losses. The ILM nomograms for the Amended LTAP for the years 2013\14 and 2014\15 are shown in Figures 5-7 and 5-8, respectively.

**Figure 5-7. ILM Nomogram for Amended LTAP Portfolio F2014**



In 2013\14, the LM and VI load and losses is shown as line A. The full dispatch of the dependable Coastal Generation, including Burrard Generating Station, is necessary to keep the required transfer at KLY and NIC (line B) within the one-hour thermal rating (line C) and the voltage stability rating (line D) of the ILM grid. After an hour, an additional 150 MW of the coastal resources or imports, such as the CE, is needed to keep the post one-hour required transfer at KLY and NIC (line H) within the continuous thermal rating of the system (line E). The dispatch of the SI generation (NIC transfer) would be restricted after an hour because the maximum dependable NIC transfer (line F) is larger than the continuous thermal rating (line E) even after full redispatch of coastal resources.

1

**Figure 5-8. ILM Nomogram for Amended LTAP Portfolio F2015**

2


3 In 2014\15, Burrard Generating Station and the CE are no longer available for  
 4 dispatch in the Amended LTAP portfolio. The dispatch of the remaining dependable  
 5 Coastal Generation results in the required transfer at KLY and NIC (line B) to be  
 6 above the continuous rating of the system (line E). This illustrates that under the  
 7 Amended LTAP scenario, unless about 850 MW of increased transfer capability is  
 8 provided on the ILM grid, or a similar amount of new coastal resources is found, the  
 9 post contingency ILM transfers will be well above the continuous thermal limit by the  
 10 winter of 2014. Unless increased transfer capability or additional coastal resources  
 11 were put in place, this would result in load shedding to maintain the system within its  
 12 thermal operating limits.

### 13 5.2.2.1 ILM Nomogram for CRP 1

14 ILM transfers for CRP 1 for the years 2013\14 and 2014\15 are shown in Figures 5-9  
 15 and 5-10 respectively.

1


**Figure 5-9. ILM Nomogram for CRP1 F2014**



2

3 In 2013\14, the full dispatch of the dependable Coastal Generation, including Burrard  
 4 Generating Station, is necessary to keep the KLY and NIC required transfer line (line  
 5 B) within the one-hour thermal rating (line C) and the voltage stability rating (line D) of  
 6 the ILM grid. After an hour, an additional 650 MW of coastal resources or imports,  
 7 such as the CE, would need to be redispatched to keep the post one-hour required  
 8 transfer at KLY and NIC (line H) within the continuous thermal rating of the system  
 9 (line E). The continuous dispatch of SI generation (NIC transfer) would be restricted  
 10 because the maximum dependable NIC transfer (line F) is larger than the continuous  
 11 thermal rating (line E).

1

**Figure 5-10. ILM Nomogram for CRP1 F2015**

2


3 In 2014\15, Burrard Generating Station and the CE are no longer forecast to be  
 4 available to be dispatched as Coastal Generation. The dispatch of the remaining  
 5 dependable Coastal Generation results in the KLY and NIC transfer line (line B) being  
 6 above the continuous rating of the system (line C) and the voltage stability limit (line  
 7 D). Under this scenario, the ATC is negative by about 1250 MW and illustrates the  
 8 need for increased transfer capability on the ILM grid in 2014.

### 9 5.2.2.2 ILM Nomogram for CRP 2

10 ILM transfers for CRP 2 for the years 2013 and 2014 are shown in Figures 5-11 and  
 11 5-12, respectively.

1

**Figure 5-11. ILM Nomogram CRP2 F2014**




2

3 In 2013\14, the full dispatch of the dependable Coastal Generation, including Burrard  
 4 Generating Station, is necessary to keep the required transfer at KLY and NIC (line  
 5 B) within the one-hour thermal rating (line C) and the voltage stability rating (line D) of  
 6 the ILM grid. After an hour, an additional 750 MW of the CE would need to be  
 7 redispatched to keep the KLY and NIC required transfers (line H) within the  
 8 continuous thermal rating of the system (line E). The dispatch of SI generation (NIC  
 9 transfer) is restricted because the maximum dependable NIC transfer (line F) is larger  
 10 than the continuous thermal rating (line E).



1

**Figure 5-12. ILM Nomogram CRP2 F2015**

2

3 In 2014\15, Burrard Generating Station and the CE are no longer forecast to be  
 4 available to be dispatched as coastal resources under CRP 2. The dispatch of the  
 5 remaining Coastal Generation results in the KLY and NIC transfer line (line B) being  
 6 above the continuous rating of the system (line C) and above the voltage stability limit  
 7 (line D). The ATC of the ILM grid is negative by about 1500 MW and this illustrates  
 8 the need for the ILM reinforcement in 2014.

### 9 5.2.2.3 ILM Cut-Plane Observations for LTAP and Contingency Portfolios


- 10 (a) An increase in ILM transfer capability is needed at its earliest in-service date  
 11 of 2014 for the Amended LTAP portfolio as well as for the Commission  
 12 approved CRPs 1 and 2.
- 13 (b) In the absence of Burrard Generating station and the CE by 2014, all three  
 14 portfolios exceed the existing continuous thermal limits of the existing ILM  
 15 grid.
- 16 (c) All three portfolios exceed the existing voltage stability limits without Burrard  
 17 Generating Station.

## 6.0 PROBABILISTIC RELIABILITY ANALYSIS

A probabilistic reliability analysis of a transmission system measures the adequacy of the system in terms of its ability to serve load. The analysis uses historical outage data to model the future random outage behaviour of system components under various loading conditions. The analysis calculates the likelihood of load being lost in terms of Expected Energy Not Served (EENS). This quantity can then be monetized by multiplying the EENS by a per unit customer damage function. The analysis does not determine the EENS if the system becomes insecure and cascades resulting in large amounts of load being lost. Nevertheless, the EENS analysis is a powerful tool for the decision-making process because it quantifies the unreliability of the system for various configurations assuming the system does not blackout.

An EENS analysis was completed in 2006 based on the NITS portfolios to determine the adequacy of the ILM grid with and without an increase in transfer capability of the ILM grid. The difference is shown in Figure 6-1. The difference in risk cost is the average value for the four years 2014 to 2018.

Figure 6-1. Saving on Risk Cost – ILM vs. Do-nothing



1 If the transfer capability of the ILM grid is not increased when it does not meet the  
2 single contingency criteria the unreliability of the system grows. Monetizing the impact  
3 of this unreliability using the per unit customer damage cost<sup>1</sup> of \$10 per kWh results  
4 in an annual cost to the customer of \$20 M per year in 2014 and increases to \$ 40 M  
5 per year by 2016. Figure 6-1 also shows the annual cost of the “do nothing” option  
6 with higher and lower damage costs. The “do nothing option” can only be applied for  
7 four years, because for subsequent years, the load cannot be served during the peak  
8 period even under system normal conditions (i.e., with all equipment in service).

## 9 **7.0 CONCLUSION**

10 A review of the results leads to the following conclusions:

11 The transfer capability of the ILM grid must be increased to meet the single  
12 contingency outage requirement for the ILM cut-plane as early as the fall of 2014 for  
13 the Amended LTAP portfolio and the Commission approved CRP 1 and CRP 2.

14 The need for increased transfer capability on the ILM grid was also confirmed in the  
15 portfolio studies analyzed in the NITS 2004 studies, during the IEP studies, and  
16 during the course of BC Hydro’s 2006 IEP/LTAP proceeding. Depending upon which  
17 of these resource scenarios is considered, increased transfer capability on the ILM  
18 grid could be needed as early as the fall of 2014 or as late as 2023.<sup>2</sup> Almost all of the  
19 portfolios studied have indicated that increased transfer capability at the earliest in-  
20 service date is needed.

21 Resource portfolios that include a repowered Burrard and/or dispatch of the CE result  
22 in a deferral of the timing of the need for increased transfer capability on the ILM grid.

---

<sup>1</sup> This is the same approach that BCTC used in a series of five EENS studies (found at [www.bctc.com/the\\_transmission\\_system/reliability\\_assessment/selected\\_tech\\_reports.htm](http://www.bctc.com/the_transmission_system/reliability_assessment/selected_tech_reports.htm)) during the VITR proceeding. These studies used a benchmark interruption cost of \$5/kWh and looked at sensitivities to other costs. \$5/kWh as a benchmark comes from a study entitled “F. Turner, et al. Reliability Worth: Development of A Relationship with Outage Magnitude, Duration and Frequency. CEA paper, March 1994.” For an explanation of the sources of all of the costs, see section 6 of the fourth of the five EENS studies, “Expected Energy Not Served (EENS) Study for Vancouver Island Transmission Reinforcement Project, Part IV: Effects of Existing HVDC on VI Power Supply Reliability, Report BCTC-SPPA-R009D, January 9, 2006,” available at the weblink given above.

<sup>2</sup> This date is based on earlier studies that applied a one-hour thermal rating only and did not account for voltage stability limits.

1 Failure to increase the transfer capability of the ILM grid when needed will result in a  
2 violation of the ILM continuous thermal limits and the voltage stability limits due to a  
3 Coastal Generation capacity shortfall, for most of the generation resource portfolios.  
4 Failure to increase the transfer capability of the ILM grid when required will also  
5 increase the unreliability of the system from an adequacy point of view and will  
6 increase the risk of cascading outages and blackouts from a security point of view.  
7 Conversely, limiting the CU on the ILM grid to be within the existing ILM TTC will  
8 result in firm load not being served and inefficient operation of the system with  
9 restrictions on remote generation dispatch flexibility. Both outcomes are unacceptable  
10 consequences.

11 BCTC needs to plan the transmission system to meet those scenarios that require  
12 additional ILM transfer capability as early as 2014 as well as dealing with scenarios  
13 where the need for incremental transfer capability might arise later. Should greater  
14 Coastal Generation and/or DSM materialize than the amounts forecast in the above-  
15 identified portfolios, it would tend to defer the need for incremental ILM transfer  
16 capability. In that event, BCTC would be in a position to consider its impact on the  
17 timing of the ILM project. However, because BCTC must also be able to deal with  
18 scenarios that require earlier in service dates, proceeding with the approvals required  
19 to increase the transfer capability of the ILM grid and preserve an in-service date as  
20 early as 2014 is recommended.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10

## APPENDIX A

### IEP/ LTAP PORTFOLIO ANALYSIS

As part of BC Hydro's 2006 IEP application, BCTC analyzed the transmission implications of seventeen resource portfolios. A complete description of these portfolios can be found in the IEP application at:

<http://www.bchydro.com/info/epi/epi43498.html>

A summary of the incremental transmission facilities required for each portfolio was presented in Table H-1 of Appendix H in BC Hydro's 2006 IEP application and is included for reference below in Table A-1.

**Table A-1. 2006 IEP Incremental Transmission Facilities**

(Note: Burrard Replacement refers to an SVC device to provide voltage support in lieu of Burrard)

Transmission Resources	Low Cost (mid-GHG)	Low Cost (GHG @ \$10/tonne)	Coal	Low Air Impacts	Low Land Impacts	Diverse Technology	100% Green	Low Air Impacts without EE 3, 4 or 5	Low Cost without Site C	Low Cost without EE 3, 4 or 5	Maintain Burrard	Maintain Burrard for Capacity	Burrard Repowering	Low Cost (up to 6,000 GWh Imports)	Low Cost (3,000 GWh Imports)	Security of Supply	Security of Supply with Insurance	
Mica G6 Transmission Reinforcement							October 2024	October 2024										
Nicola Substation 500 kV Reconfiguration	October 2012	October 2011	October 2011	October 2012	October 2011	October 2012	October 2012	October 2010	October 2012	October 2010	October 2012		October 2010	October 2010	October 2012	October 2012	October 2010	October 2010
Revelstoke G5 Transmission Reinforcement	October 2012	October 2011	October 2011	October 2012	October 2011	October 2012	October 2012	October 2010	October 2012	October 2010	October 2012		October 2010	October 2010	October 2012	October 2010	October 2010	October 2010
Revelstoke G6 Transmission Reinforcement				October 2024		October 2024	October 2024	October 2023	October 2024	October 2024					October 2024	October 2024		
Selkirk to Nicola/Ashton Creek Transmission Reinforcement	October 2009	October 2009	October 2009	October 2009	October 2009	October 2009	October 2009	October 2009	October 2009	October 2009	October 2009	October 2009	October 2009	October 2009	October 2009	October 2009	October 2009	October 2009
Kelly Lake to Cheekye 500 kV line (5L46)		October 2023	October 2021							October 2019		October 2022						
Mica G5 Transmission Reinforcement	October 2024	October 2024	October 2024	October 2024		October 2024	October 2020	October 2020	October 2024	October 2024	October 2024		October 2024	October 2024	October 2024	October 2014	October 2024	October 2024
Nicola to Meridian 500 kV line (5L83)	October 2013	October 2013	October 2013	October 2013		October 2013	October 2013	October 2013	October 2013	October 2013	October 2013	October 2013	October 2013	October 2020	October 2013	October 2013	October 2014	October 2016
2nd Vancouver Island 230 kV line	October 2023	October 2020	October 2020	October 2024	October 2024	October 2022		October 2020	October 2023	October 2019	October 2021	October 2022	October 2021	October 2023	October 2022			
Burrard Replacement	April 2014	April 2014	April 2014	April 2014	April 2014	April 2014	April 2014	April 2014	April 2014	April 2014	April 2014			April 2014	April 2014	April 2014	April 2014	April 2014

1 Thirteen of the seventeen portfolios required incremental facilities on the ILM grid  
 2 (indicated as 5L83) by the earliest feasible in-service date. Three of the portfolios  
 3 required in service dates from by 2014 to 2020, and one portfolio was constructed to  
 4 require no incremental facilities on the ILM grid.

5 During BC Hydro's 2006 IEP hearings, BCTC conducted an analysis of the ILM  
 6 requirements for the LTAP, CRP1, and CRP2 portfolios. The analysis was based on  
 7 the December 2006 load forecast. It examined the impact of re-powering Burrard,  
 8 applying the CE as a network resource, and dispatching maximum or dependable  
 9 capacity of Interior generation resources on the timing of incremental facilities on the  
 10 ILM grid. Results of the analysis are published and are summarized in Table A-2 for  
 11 reference:

12 **Table A-2. Resource Portfolios Reviewed During 2006 IEP Hearings**

	<b>Resource Portfolios Reviewed During 2006 IEP Hearings</b>	<b>Required ILM In-Service Date</b>
1	LTAP + Max Interior Dispatch	October 2014
2	CRP1 + Max Interior Dispatch	October 2014
3	CRP2 + Max Interior Dispatch	October 2014
4	LTAP + Re-powered BGS + Max Interior Dispatch	October 2014
5	CRP1 + Re-powered BGS + Max Interior Dispatch	October 2014
6	CRP2 + Re-powered BGS + Max Interior Dispatch	October 2014
7	LTAP + Re-powered BGS + CE + Max Interior Dispatch	October 2020
8	CRP1 + Re-powered BGS + CE + Max Interior Dispatch	October 2017
9	CRP2 + Re-powered BGS + CE + Max Interior Dispatch	October 2017
10	LTAP + Dependable Interior Dispatch	October 2018
11	CRP1 + Dependable Interior Dispatch	October 2014
12	CRP2 + Dependable Interior Dispatch	October 2014
13	LTAP + Re-powered BGS + Dependable Interior Dispatch	October 2023
14	CRP1 + Re-powered BGS + Dependable Interior Dispatch	October 2014
15	CRP2 + Re-powered BGS + Dependable Interior Dispatch	October 2014
16	LTAP + Re-powered BGS + CE + Dependable Interior Dispatch	October 2023
17	CRP1 + Re-powered BGS + CE + Dependable Interior Dispatch	October 2019
18	CRP2 + Re-powered BGS + CE + Dependable Interior Dispatch	October 2018

1  
2 The need for increased transfer capacity on the ILM grid was also analyzed in the  
3 2004 NITS studies, in studies prior to the submission of the BC Hydro's 2006 IEP  
4 application, and in studies during BC Hydro's 2006 IEP/LTAP proceeding. All of these  
5 studies used the N-1 thermal nomogram with one hour continuous thermal rating of  
6 the existing ILM grid to determine timing of the peak hour negative ATC of the grid.  
7 Each study was conducted based on the latest set of available load forecasts, the  
8 most likely resource scenarios, and the firm export possibilities at the time of study.  
9 The analysis data and assumptions are listed in Table A-3.

10 **Table A-3. Analysis Data and Assumptions**

	<b>Studies</b>	<b>Load Forecast</b>	<b>Resource Portfolios</b>	<b>Export Western Inter-tie</b>
1	NITS2004 (8 scenarios)	October 2004 coincidental normal and high	Base resource plan, Alternative 1, Alternative 2, Alternative 3	230 MW and 730 MW
2	Before 2006 IEP Submission (17 scenarios)	December 2005 coincidental normal and high	Coal, Low air impacts, Low land impacts, Diverse technology, 100% Green, Low cost (mid GHG), Low cost (GHG@ \$10/tonne), Maintain Burrard, Low cost (3000 GWh import), Maintain Burrard for capacity, Low cost without Site C, Burrard re-powering, Low cost (up to 6000 GWh imports), Security of supply with insurance, Low air impact w/o EE3 or 4 or 5, Security of Supply, Low cost impact w/o EE3 or 4 or 5	230 MW
3	During 2006 IEP Submission (18 scenarios)	December 2006 coincidental normal and high	LTAP+Max Interior Dispatch, CRP1+Max Interior Dispatch, CRP2+Max Interior Dispatch, LTAP+Max Interior Dispatch+BGS repowering, CRP1+Max Interior Dispatch+BGS repowering, CRP2+Max Interior Dispatch+BGS repowering, LTAP+Max Interior Dispatch+BGS repowering+CE, CRP1+Max Interior Dispatch+BGS repowering+CE, CRP2+Max Interior Dispatch+BGS repowering+CE, LTAP+Dep Interior Dispatch, CRP1+Dep Interior Dispatch, CRP2+Dep Interior Dispatch, LTAP+Dep Interior Dispatch+BGS repowering, CRP1+Dep Interior Dispatch+BGS repowering, CRP2+Dep Interior Dispatch+BGS repowering, LTAP+Dep Interior Dispatch+BGS repowering+CE, CRP1+Dep Interior Dispatch+BGS repowering+CE, CRP2+Dep Interior Dispatch+BGS repowering+CE	230 MW

11



1           The need for incremental facilities on the ILM grid was recognized in the eight NITS  
2           2004 load/resource scenarios. In all of the NITS2004 scenarios, the ATC of the ILM  
3           grid would be depleted before a new ILM transmission line could be built. As a result,  
4           the earliest feasible in service date of a new transmission line was considered the  
5           earliest date for increasing the transfer capability of the ILM grid.

6           The need for the increased transfer capability on the ILM grid was confirmed in  
7           sixteen of the seventeen portfolios that BCTC reviewed prior to submission of the  
8           2006 IEP. In terms of ILM's ISD, thirteen of the reviewed portfolios had 2013, one  
9           required a 2014, one a 2016, and one portfolio had a 2020. The only load/resource  
10          portfolio that did not require incremental facilities on the ILM transmission grid was  
11          based on the addition of approximately 1700 MW new thermal generation near the  
12          load center.